

Cigre WG A3-06 “HV Equipment Reliability”

Gas Insulated Substations (GIS) Reliability Results

Participation in the survey (2004-2007):



24 countries, 55 utilities

Ø annual reported population 22240 CB-bays

Evaluation made for 2 datasets:

	Service experience [CB-bay-years]	Number of major failures MaF	Number of minor failures MiF
All data	88948	326	1505
Without countries 14 and 23	7158	102	970

WB A3.06 - Reliability of HV equipment – GIS failure rates




WB A3.06 - Reliability of HV equipment – GIS failure rates

Voltage class	Outdoor GIS Major failure frequency [MaF/100 CB-bay-years] all data			Result of null and alternate hypothesis test with indoor GIS data results
	Point estimation	Lower limit	Upper limit	
60≤U<100 kV	0,41	0,34	0,50	Indoor better than outdoor
100≤U<200 kV	0,28	0,18	0,41	equal
200≤U<300 kV	0,34	0,20	0,53	equal
300≤U<500 kV	0,70	0,52	0,92	Indoor worse than outdoor
500≤U<700 kV	0,56	0,32	0,91	equal
Total	0,43	0,38	0,49	Indoor better than outdoor

Statistic calculations for 95% of confidence level and null and alternate hypothesis tests for comparisons

Voltage class	[MaF/100 CB-bay-years]		Test of null and alternate hypothesis	[MaF/100 CB-bay-years]		Test of null and alternate hypothesis
	2 nd survey indoor GIS	3 rd survey indoor GIS		2 nd survey outdoor GIS	3 rd survey outdoor GIS	
60≤U<100 kV	0,08	0,09	equal	0,03	0,51	3 rd worse than 2 nd
100≤U<200 kV	0,78	0,22	3 rd better than 2nd	0,12	0,29	3 rd worse than 2 nd
200≤U<300 kV	1,12	0,33	3 rd better than 2nd	0,46	0,34	equal
300≤U<500 kV	3,09	1,34	3 rd better than 2nd	2,36	0,71	3 rd better than 2 nd
500≤U<700 kV	2,20	0,00	3 rd better than 2nd	0,16	0,56	3 rd worse than 2 nd
≥700 kV	6,00	2,08	3 rd better than 2nd	0,21	0,49	3 rd worse than 2 nd
Total	0,79	0,28	3 rd better than 2nd	0,03	0,51	3 rd worse than 2 nd


WB A3.06 - Reliability of HV equipment – GIS failure rates




	before 1979	1979-1983	1984-1988	1989-1993	1994-1998	1999-2003	2004-2007
60≤U<100 kV	0,51	0,39	0,50	0,27	0,20	0,08	0,40
100≤U<200 kV	1,98	1,29	0,64	0,11	0,13	0,08	0,33
200≤U<300 kV	0,14	0,14	0,13	0,49	0,46	0,40	0,22
300≤U<500 kV	4,05	1,99	1,36	0,61	0,34	0,31	0,58
500≤U<700 kV	0,00	1,39	0,00	0,39	0,58	0,19	0,00

WB A3.06 - Reliability of HV equipment – GIS failure characteristics

GIS equipment major failures
(MaF) voltage classes distribution
(all data)



Major failure mode (all data)



GIS analysis content (tables, graphs, comparison with 1995 survey results, findings and commentary):

- Population, major and minor failures, major failure rates per 100*CB-bay-year for GIS location, type of enclosure and design (GIS, MTS) per voltage classes and age
- Failure characteristics (component, failure mode, failed subassembly, service circumstances, origin, primary cause, environmental contribution, repair, consequential measures and their correlations) per age, location resp.
- Individual GIS equipment failure rates (CB, DS/ES, IT, other parts as bushings, busbars, busducts, SA)
- GIS practices and strategies (on-site HV testing, monitoring and diagnostics, specific service problems, major maintenance ,extension, new technologies, functional spec. and turnkey projects experience)

Brochure will be published in 2011